



WSAA PRODUCT APPRAISAL CERTIFICATE

vonRoll hydro (Suisse) ag ECOPUR® and DUCPUR ISO Sized Ductile Iron Pipes

This Appraisal is for a range of ECOPUR® and DUCPUR® ISO sized polyurethane lined ductile iron pipes with an elastomeric push-in TYTON JOINT in sizes DN 80 to DN 600 with 6 metre effective lengths, manufactured in conformance with EN 545:2010.

This Issue 3 is a replacement for the previous version of the appraisal which had reached its 5-year expiry date.

The pipe is not OD compatible with AS/NZS 2280 pipes and fittings. Pressure classifications are specific to the nominal size of the pipe.

ECOPUR pipes are internally lined with green coloured polyurethane and externally coated with black coloured polyurethane.

DUCPUR pipes are internally lined with green coloured polyurethane and externally coated with 400 g/m² of metallic zinc aluminium (85/15) alloy and a blue-coloured two-part epoxy finishing layer.

AS/NZS 2280 ISO ductile iron polymeric coated fittings in sizes 100 to DN 300 utilise a transition gasket to accommodate ISO sized pipe OD's. A complete range of ISO compatible EN 545 ductile iron fittings is also available.

A listing of relevant Quality and Product Certification Certificates and details of products are included in the attached Schedules A and B.

Product Category	Ductile Iron Pipes
PA Number:	PA 1430 Issue 3
Supplier	vonRoll hydro (Suisse) ag via Reece Australia Pty Ltd
Brand	DUCPUR and ECOPUR
Standards	EN 545:2010 <i>Ductile iron pipes, fittings, accessories and their joints for water pipelines – Requirements and test methods</i>
WSAA Product Specification	WSA PS 202 <i>Ductile Iron Pipes and Fittings (ISO Sized) for Pressure Applications – Drinking Water and Non-Drinking Water Supply</i>
Issue date	18 November 2021
Expiry date	17 November 2026
Recommendations	It is recommended that WSAA members, subject to any specific requirements of the member, accept or authorise the vonRoll ECOPUR and DUCPUR range of ductile iron ISO pipes and fittings as detailed in the report for use in water supply and sewerage applications subject to any relevant conditions relating to the design, installation and acceptance testing being in accordance with the relevant WSAA Codes and manufacturer's requirements.
Disclaimer	The disclaimer on Page 2 explains a number of very important limits on your ability to rely on the information in this Product Appraisal Certificate and the assessment criteria used to underlay it. Please read it carefully and take it into account when considering the content in this Certificate.

1. Disclaimer

This Product Appraisal Certificate (Certificate) is issued by WSAA on the understanding that:

This Certificate applies to the product(s) as submitted in Schedule A. Any changes to the product(s) either minor or major shall void this Certificate.

To maintain the recommendations of this Certificate any such changes shall be detailed and notified to the Product Appraisal Manager for consideration and review of the Certificate including the product appraisal criteria underlying it and appropriate action. Appraisals and their recommendations will be the subject of continuous review dependent upon the satisfactory performance of products.

WSAA reserves the right to undertake random audits of product manufacture and installation. Where products fail to maintain appraised performance requirements the appraisal and its recommendations may be modified and reissued. Certificates will be reviewed and reissued at regular intervals not exceeding five (5) years.

WSAA reserves the right to withdraw this Certificate at any time in its sole and absolute discretion for any reason.

The following information explains a number of very important limits on your ability to rely on the information in this Certificate. Please read it carefully and take it into account when considering the contents of this Certificate.

Any enquiries regarding this Certificate should be directed to the Product Appraisal Manager Phone: 03 8605 7601 email carl.radford@wsaa.asn.au.

1.1. Issue of Certificate

This Certificate has been published and/or prepared by WSAA and nominated Project Manager and peer group of technical specialists (the Publishers).

The Certificate and the underlying product appraisal criteria have been prepared for use within Australia only by technical specialists that have expertise in the function of products such as those appraised in the Certificate (the Recipients).

By accepting this Certificate, the Recipient acknowledges and represents to the Publisher(s) and each person involved in the preparation of the Certificate and product appraisal criteria underlying it that the Recipient has understood and accepted the terms of this Disclaimer.

1.2. Limits on Reliance on Information and Recommendations

1.2.1. Disclaimer of liability

Neither the Publisher(s) nor any person involved in the preparation of the Certificate and product appraisal criteria underlying it accept(s) any liability for any loss or damage suffered by any person however caused (including negligence or the omission by any person to do anything) relating in any way to the Certificate or the product appraisal criteria underlying it. This includes (without limitation) any liability for any recommendation or information in the Certificate or any errors or omissions.

1.2.2. Intellectual Property and other rights

WSAA does not undertake any assessment of whether the importation, manufacture, sale or use of the Product the subject of this Certificate infringes the intellectual property rights or proprietary rights of any person. Recipients of the Certificate should undertake their own assessment of whether (as relevant) the importation, manufacture, sale or use of the relevant Products infringe the intellectual property rights or other proprietary rights of any person. If the Product infringes intellectual property rights or other proprietary rights there is potential for the supply of the Products to be interrupted.

From time to time WSAA and the other Publishers may receive notice of allegations that the importation, manufacture, sale or use of the Product infringes intellectual property rights or other proprietary rights. WSAA's policy is to not refer to such allegations in its Certificate or take any other steps to put Recipients on notice of such allegations. If, however, WSAA becomes aware that the allegations have been admitted or proved in Court, then WSAA may, at its discretion, take such steps as it considers appropriate. As such, Recipients acknowledge, agree and accept that WSAA may have information in its possession about intellectual property rights infringement allegations or other infringement allegations in relation to the Product which are not referred to or disclosed in this Certificate and which are not otherwise communicated to Recipients.

1.2.3. Need for independent assessment

The information and any recommendation contained (expressly or by implication) in this Certificate are provided in good faith (and subject to the limitations noted in this Certificate). However, you should treat the information as indicative only. You should not rely on that information or any such recommendation except to the extent that you reach an agreement to the contrary with the Publisher(s).

This Certificate does not contain all information that a person might require for the purposes of assessing any product discussed or appraised within it. The product appraisal criteria used in preparing this Certificate may not address all relevant aspects of the Product.

Recipients should seek independent evidence of any matter which is material to their decisions in connection with an assessment of the Product and consult their own advisers for any technical information required. Any decision to use the Product should take into account the reliability of that independent evidence obtained by the Recipient regarding the Product. Recipients should also independently verify and assess the appropriateness of any recommendation in the Certificate, especially given that any recommendation will not take into account a Recipient's particular needs or circumstances.

WSAA has not evaluated the extent of the product liability and professional indemnity insurance that the provider of the product maintains. Recipients should ensure that they evaluate the allocation of liability for product defects and any professional advice obtained in relation to the product or its specification including the requirements for product liability and professional indemnity insurance.

1.3. No Updating

Neither the Publisher(s) nor any person involved in the preparation of this Certificate or the product appraisal criteria underlying it [has] [have] any obligation to notify you of any change in the information contained in this Certificate or of any new information concerning the Publisher(s) or the Product or any other matter.

1.4. No Warranty

The Publisher(s) do[es] not, in any way, warrant that steps have been taken to verify or audit the accuracy or completeness of the information in this Certificate, or the accuracy, completeness or reasonableness of any recommendation in this Certificate

QUALITY AND PRODUCT CERTIFICATIONS

Copies of the following Quality and Product Certification Certificates are available from WSAA.

TABLE A1 VONROLL HYDRO (SUISSE) AG – MANAGEMENT SYSTEMS

Choindez 33 2830 Courrendlin Switzerland	
Quality Systems Standard	ISO 9001:2015
Certification Licence No.	H20430
Certifying Agency	SQS
Current Date of Certification	1 April 2020
Expiry Date of Certification	31 March 2023


TABLE A2 VONROLL HYDRO (SUISSE) AG – PRODUCT CERTIFICATION

Choindez 33 2830 Courrendlin Switzerland	
Product Standard/Spec.	EN 545:2010
Certificate No.	11-7416-1 (EN)
Issuing Certification Body	MPA NRW
Current Date of Certification	20 February 2019
Expiry Date of Certification	19 February 2022



ECOPUR – Unique full protection thanks to integral polyurethane (PUR) coating technology

For use in all soils – efficient protection against aggressive media and stray currents




ZEROWATERLOSS
vonroll-hydro.world



DUCPUR – For water and wastewater

New areas of application with zinc-aluminium outside coating



ZEROWATERLOSS
vonroll-hydro.world

SUPPLIER CONTACTS

vonRoll hydro (Suisse) ag

vonRoll Strasse 24
Oensingen Solthurn Switzerland 4702

Contact:

Vincent Voyame
Mobile: +41 62 388 1220
Email: vincent.voyame@vonroll-hydro.world
Website: <https://www.vonroll-hydro.world/en/>

Reece Australia Pty Ltd

118 Burwood Highway
Burwood Vic 3125
Web: <https://www.reece.com.au/civil>

Contact:

Charles Cauchi
Mobile: 0429 926488
Email: charles.cauchi@reece.com.au

Viadux:

Website store locator: <https://www.viadux.com.au/about-us/locations>

Reece Civil Stores:

Website store locator: <https://www.reece.com.au/aboutus/contactus>